



AMERICAN COOLING TECHNOLOGY, Inc.
P.O. BOX 308 * 310 EMIG ROAD
EMIGSVILLE, PA 17318-0308
FAX: (717) 767-3658
(717) 767-2775

WIRING DIAGRAM EZ-9 W/ (2) CS SERIES COND DWG NO. 510-036

NOTE: ELECTRICAL PANEL MUST BE
MOUNTED IN A DRY LOCATION WITH
AN AMBIENT TEMP UNDER 150 DEG F

ELECTRICAL PANEL
P/N 550-009

POS. BATTERY TERMINAL
4 GA WIRE PROVIDED BY OTHERS

IGNITION CONNECTION
CAPABLE OF AN
ADDITIONAL 20 AMP
DRAW

